



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME KENDALL BROOK APARTMENTS					DATE 7/29/2014	SIGNATURE	
LOCATION 1200 KENDALL DR, SAN BERNARDINO, CA 92407					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 4/30/2015	
MAILING ADDRESS 1200 KENDALL DR, SAN BERNARDINO CA 92407					REHS Dior Porter		
FA # FA0006349	PR # PR0014850	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Office Spa		
TIME IN 1:07 PM	TIME OUT 1:30 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED		
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	39
volume (gal)	1,170
area (sq ft)	No Data
occupancy	7

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Permit suspended due to excessive chlorine. Maintain chlorine at 1.0-10ppm. Closure sign posted. Contact information for the program of Environmental Health left with the manager. Contact the program when correction has been made. 800-442-2283
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Measured chlorine in excess of 10ppm. Maintain chlorine at 1.0-10ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid in excess of 100ppm. Maintain cyanuric acid at or below 100ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments