



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>LAS BRISAS APARTMENTS</b>					DATE <b>7/30/2014</b>	SIGNATURE	
LOCATION <b>1319 SPRINGFIELD 128, UPLAND, CA 91786</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>6/30/2015</b>	
MAILING ADDRESS <b>4111 SEPULVEDA BL, SHERMAN OAKS CA 91403</b>					REHS <b>Shannon Johnson</b>		
FA # <b>FA0008606</b>	PR # <b>PR0014394</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3620</b>	PROGRAM IDENTIFIER: <b>West Pool</b>		
TIME IN <b>1:01 PM</b>	TIME OUT <b>1:36 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>001 - INSPECTION - ROUTINE</b>		
					RESULT: <b>05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED</b>		
					ACTION: <b>03 - REINSPECTION REQUIRED</b>		

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**94**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	82.5
observed flow (gpm)	No Data
required flow (gpm)	34
volume (gal)	12,145
area (sq ft)	406
occupancy	40

**36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed the free chlorine residual to be 1 ppm.
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR - 65529</b>	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

**36K427 Safety - Safety Signs**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed no safety sign with information regarding the nearest emergency services other than 911.
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR 24 - 3120B</b>	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
 RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>LAS BRISAS APARTMENTS</b>		DATE <b>7/30/2014</b>	SIGNATURE
LOCATION <b>1319 SPRINGFIELD 128, UPLAND, CA 91786</b>		REHS <b>Shannon Johnson</b>	

**36K440 Enclosure - Non-Critical - Enclosure/Gates Non-Drowning Hazard**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed multiple areas at the bottom of the fencing for the facility were gaps exist more than 4 inches. No gaps greater than 4 inches may be present at any place of this fencing. This must be repaired by October 1, 2014.
	Not In Compliance	
Violation Reference - HSC - 3119B		

**Violation Description:** The enclosure, doors and gates shall meet all requirements in the California Code of Regulations. Fencing/gates shall be maintained in good repair. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

**Overall Inspection Comments**

All gaps greater than 4 inches, at the bottom of this facility's fence, must be eliminated by October 1, 2014. If compliance is not achieved at that time, a charged inspection will ensue.

The pump/equipment enclosure is located in an underground confined space and was not inspected.

**Photo Attachments:**

No Photo Attachments