



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>LOS RANCHOS</b>					DATE <b>7/30/2014</b>	SIGNATURE <i>See Pool Report</i>	
LOCATION <b>20843 WAALEW RD, APPLE VALLEY, CA 92307</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>2/28/2015</b>	
MAILING ADDRESS <b>20843 WAALEW RD, APPLE VALLEY, CA 92307</b>					REHS <b>John Ramos</b>		
FA # <b>FA0004537</b>	PR # <b>PR0016316</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	PROGRAM IDENTIFIER: <b>East Spa</b>		
TIME IN <b>10:44 AM</b>	TIME OUT <b>11:16 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>001 - INSPECTION - ROUTINE</b>		
					RESULT: <b>03 - CORRECTIVE ACTION / NO FOLLOW UP REQ</b>		
					ACTION: <b>01 - NO FURTHER ACTION REQUIRED</b>		

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**94**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	104.0
observed flow (gpm)	No Data
required flow (gpm)	65
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K402 Water Quality - Critical - Lack of Disinfectant**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Comply by: <b>8/1/2014</b>	<b>Inspector Comments:</b> Observed chlorine at 0.3 ppm. Maintain chlorine between 1.0 and 10.0 ppm. Corrected to 5.6ppm
	Complied on <b>7/30/2014</b>	
	Violation Reference - <b>CCR - 65529</b>	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed stuck flow meter. Repair or replace flow meter.
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR - 3125B</b>	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**Overall Inspection Comments**

Correct the above noted violations.

If you have any questions contact John Ramos at (800) 442-2283.  
 Our office has moved to 15900 Smoke Tree Street, Hesperia, CA 92345.

**Photo Attachments:**  
 No Photo Attachments