



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

| | | | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|-------------------|---|---------------------------------------|--|
| FACILITY NAME PONDEROSA PINES CHRISTIAN CAMP | | | | | DATE 7/31/2014 | SIGNATURE | |
| LOCATION 31324 GREEN VALLEY LAKE RD, RUNNING SPRINGS, CA 92382 | | | | | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 8/31/2014 | |
| MAILING ADDRESS PO BOX 1247, RUNNING SPRINGS CA 92382 | | | | | REHS Dior Porter | | |
| FA # FA0006905 | PR # PR0008312 | SR # Not Specified | CO # Not Specified | PE 3620 | PROGRAM IDENTIFIER: Pool | | |
| TIME IN 10:18 AM | TIME OUT 10:45 AM | CONTACT Not Captured | | | SERVICE: 001 - INSPECTION - ROUTINE | | |
| | | | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ | | |
| | | | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | | |

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

98

SCORE

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 0 |
| volume (gal) | 110,000 |
| area (sq ft) | No Data |
| occupancy | 110 |

36K448 Equipment - Flow Meter

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Repair the stuck flow meter. The flow meter is essential for determining the flow rate. |
| | Not In Compliance | |
| | Violation Reference - CCR - 3125B | |

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments