



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT




www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME 24 HOUR FITNESS 920				DATE 7/28/2014	SIGNATURE	
LOCATION 2580 ARCHIBALD AV, ONTARIO, CA 91761				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2014	
MAILING ADDRESS PO BOX 2409, CARLSBAD CA 92018				<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Veronica Martinez		
FA # FA0017069	PR # PR0023059	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa	
TIME IN 10:31 AM	TIME OUT 10:45 AM	CONTACT Not Captured			SERVICE: 008 - INSPECTION - ATTEMPTED	
					RESULT: 00 - NOT APPLICABLE	
					ACTION: 00 - NOT APPLICABLE	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed spa voluntarily closed and sectioned off with caution tape. Pool maintenance stated that a faulty solenoid for the chlorine feeder was replaced. Spa was observed to be empty of water and refill process commenced. Will reinspect spa before 7/31/14.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments