



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN VICTORVILLE				DATE 8/1/2014	SIGNATURE <i>[Signature]</i>
LOCATION 15494 PALMDALE RD, VICTORVILLE, CA 92392				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 3/31/2014
MAILING ADDRESS 20473 VALLEY BL, WALNUT CA 91789				REHS Jennifer Osorio	
FA # FA0004497	PR # PR0013983	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE
TIME IN 3:15 PM	TIME OUT 4:12 PM	CONTACT Not Captured			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

72

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	220
volume (gal)	105,673
area (sq ft)	2,975
occupancy	146

36K995 Permit - Suspension

CRITICAL

POINTS NA	Compliance Date: Not Specified	Inspector Comments: The permit is suspended due to chlorine levels exceeding 10 ppm and pH below 7.0. Per operator, pool is closed for public use due to change in ownership. Contact Environmental Health Services at 1-800-442-2283 when the pool is ready to be opened.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed chlorine above 10.0 ppm. Per pool service, added high levels of chlorine due to the pool being green. Ensure chlorine is maintained between 1.5-10 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K406 Water Quality - Critical - pH High/Low

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed pH at 6.8. Ensure pH is maintained between 7.2-8.0.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K416 Water Quality - Non-Critical - Clarity

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed pool cloudy, but main drain visible. Pool service currently cleaning pool. Maintain water clear so that main drain is visible.
	Not In Compliance	
	Violation Reference - CCR - 65527, 65543	

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. Under no circumstances shall the pool be used if the main drain is not clearly visible from the deck. The water of every wading pool shall be kept sufficiently clear so that the bottom of the wading pool will be visible at all times.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN VICTORVILLE	DATE 8/1/2014	SIGNATURE
LOCATION 15494 PALMDALE RD, VICTORVILLE, CA 92392		REHS Jennifer Osorio

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed all signs missing. Per operator, pool is not in use due to new ownership. Ensure all required signs are posted prior to opening.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no site glass in backwash line. Provide.
	Not In Compliance	
	Violation Reference - HSC - 3120B, 3132B, 3141B	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed flow meter inoperable. Ensure flow meter is functional and at the appropriate flow rate.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no records or pool kit. Ensure daily records are kept and pool kit is available.
	Not In Compliance	
	Violation Reference - CCR - 65523, 65529	

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN VICTORVILLE	DATE 8/1/2014	SIGNATURE
LOCATION 15494 PALMDALE RD, VICTORVILLE, CA 92392		REHS Jennifer Osorio

36K460 Skimmers - Requirements

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed some skimmers missing a weir. Provide. Observed no water flow direction labels in the pump room. Provide directional labels and ensure skimmer/main drain valves are labeled.
	Not In Compliance	
	Violation Reference - CCR - 65533, 3136B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

36K462 Plumbing - Backflow Protection

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no backflow prevention on fill line and fill line is below the coping of the pool. Provide backflow device or ensure fill line is a minimum of 1 inch above the coping of the pool.
	Not In Compliance	
	Violation Reference - CCR - 3141B, 3118B	

Violation Description: There shall be no direct connection between any potable water supply system and the pool or its piping system unless protected by a backflow prevention device in accordance with Chapter 6 of the California Plumbing Code. There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system. Potable water outlets with hose attachments shall be protected by a nonremovable hose bibb backflow preventer, a nonremovable hose bibb vacuum breaker, or by an atmospheric vacuum breaker.

36K468 Construction - Markings

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed missing and broken tile throughout the pool. Repair/replace.
	Not In Compliance	
	Violation Reference - CCR - 3110B	

Violation Description: The water depth shall be clearly marked at the following locations: maximum depth; minimum depth; each end; both sides at each end; at the break in the bottom slope between the shallow and deep portions of the pool; and along the perimeter of the pool at distances not to exceed 25 feet. Pools with a maximum water depth greater than 5 feet shall have a slip resistant tile a minimum of 4 inches and not greater than 6 inches wide of a color contrasting with the background of the pool shell across the bottom of the pool where the water depth is 4 1/2 feet. For pool water depths 6 feet and shallower no diving markers with the universal symbol of no diving shall be installed on the deck directly adjacent to the depth markers.

No markings, designs or lettering shall be permitted on the pool shell except for slip resistant lane markings, depth marking lines and safety markings.

36K470 Construction - Alteration - Submit Plans

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Per operator, new owners will be remodeling the pool. Ensure no construction takes plans without approved plans from Environmental Health Services. Contact 800-442-2283 and our Plan Check section for requirements and approval prior to any construction, remodel or alteration of pool area and/or equipment.
	Not In Compliance	
	Violation Reference - CCR - 3103B.1	

Violation Description: A person proposing to construct, renovate or alter a pool, ancillary facilities or equipment and appurtenances shall submit plans and specifications to DEHS for review and written approval prior to commencing construction and shall first be cleared by DEHS before substitution if not an exact duplicate of the units being changed or replaced.

36K476 Decking - Requirements

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed deck deteriorating. Repair by 2015.
	Not In Compliance	
	Violation Reference - CCR - 3114B	

Violation Description: A minimum continuous and unobstructed 4-foot wide slip resistant, cleanable, nonabrasive deck area of concrete or like material shall be provided flush with the top of the pool coping extending completely around the pool, and the deck area shall further extend 4 feet both sides and rear of any diving board, fixed disabled access assistance device or slide and their appurtenances. Deck shall be maintained in good repair.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments