





County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME QUALITY INN				DATE 8/1/2014	SIGNATURE	
LOCATION 1750 S WATERMAN AV, SAN BERNARDINO, CA 92408				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 1/31/2015	
MAILING ADDRESS 1750 S WATERMAN AV, SAN BERNARDINO, CA 92408				REHS John Babalola		
FA # FA0006654	PR # PR0014803	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa	
TIME IN 5:08 PM	TIME OUT 5:39 PM	CONTACT Not Captured			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPENED	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	6

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: The free chlorine level is still observed high, 13.0 ppm, at the time of re-inspection today. Maintain the free chlorine level at legal levels between 1.5 ppm and 10.0 ppm at all times. Note: Correction is being made. The spa can now re-open for use.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments