



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME ORANGEWOOD APARTMENTS					DATE 8/4/2014	SIGNATURE	
LOCATION 25957 REDLANDS BL, REDLANDS, CA 92373					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015	
MAILING ADDRESS 25957 REDLANDS BL, REDLANDS, CA 92373					REHS Amanda Gaspard		
FA # FA0006180	PR # PR0015555	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Office Pool		
TIME IN 10:08 AM	TIME OUT 10:39 AM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED		
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

90

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	40
required flow (gpm)	43
volume (gal)	15,778
area (sq ft)	495
occupancy	24

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Permit is suspended. Pool is closed due to high free chlorine levels. Contact the County of San Bernardino, Division of Environmental Health Services (DEHS) when compliance is reached. Maintain pool closed until re-opened by DEHS inspector.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine residual at 0.03 ppm. Stabilizer (cyanuric acid) is being utilized. Ensure that free chlorine level is between 1.5 and 10.0 ppm (since cyanuric acid is being utilized as a stabilizer). If a stabilizer is not used, ensure that chlorine level is between 1.0 and 10.0 ppm. Pool service personnel were on site during time of inspection. They added chlorine. By the end of the inspection, observed free chlorine in excess of 11.0 ppm. Pool is closed.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME ORANGEWOOD APARTMENTS	DATE 8/4/2014	SIGNATURE
LOCATION 25957 REDLANDS BL, REDLANDS, CA 92373	REHS Amanda Gaspard	

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed that the capacity sign was blank.
	Not In Compliance	<u>Fill out capacity sign.</u>
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K452 Maintenance - Flow Rate/Turnover Time

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed pool flow rate at 40 GPM. Required flow rate is 43 GPM.
	Not In Compliance	Ensure to have an adequate flow rate.
	Violation Reference - CCR 24 - 3124B	(Pool service personnel arrived on site during inspection, and conducted backwash. Observed flow rate at 75 GPM after backwash.)

Violation Description: The recirculation system shall have the capacity to provide a complete turnover of pool water in:

- 1. One-half hour or less for a spa pool;
 - 2. One-half hour or less for a spray ground;
 - 3. One hour or less for a wading pool;
 - 4. Two hours or less for a medical pool; and
 - 5. Six hours or less for all other types of public pools.
- The variation in flow of an operating recirculation system shall be such as not to reduce the flow below 75 percent of the rate required.

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed that daily logs were not being properly maintained. Observed that there were not entries every day in the log.
	Not In Compliance	Ensure to maintain daily logs regarding operation, including readings of disinfectant residual, pH, stabilizer and maintenance procedures such as cleaning of filters and quantity of chemicals used. Maintain daily records for at least one year.
	Violation Reference - CCR - 65523, 65529	

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

Overall Inspection Comments

See operator's signature on last inspection report (facility has multiple permits).

Photo Attachments:

No Photo Attachments