



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME GOOD NITE INN					DATE 8/4/2014	SIGNATURE	
LOCATION 1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2014	
MAILING ADDRESS 1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374					REHS Amanda Gaspard		
FA # FA0004817	PR # PR0015219	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN 4:01 PM	TIME OUT 4:50 PM	CONTACT Not Captured			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

86

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	55
required flow (gpm)	68
volume (gal)	24,544
area (sq ft)	595
occupancy	29

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Permit is suspended. Pool is closed due to poor water clarity. Contact the County of San Bernardino, Division of Environmental Health Services (DEHS) when compliance is reached. Maintain pool closed until re-opened by DEHS inspector.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K422 Safety - Critical - Unsafe/Hazardous Conditions

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed that the water clarity in the pool was extremely poor. Observed that the main drains could not be readily seen from the pool deck (the main drains are split; when standing on the pool deck, the second/opposite main drain could not be readily seen). Ensure that pool water is transparent and free from cloudiness. Maintain good water clarity at all times. The pool is now closed due to poor water clarity. Contact the County of San Bernardino, Division of Environmental Health Services (DEHS) when compliance is reached. Maintain pool closed until re-opened by DEHS inspector.
	Not In Compliance	
	Violation Reference - CCR - 116040, 65545, 116049	

Violation Description: Every person operating or maintaining a public swimming pool must do so in a sanitary, healthful and safe manner. Unhealthful, unsafe or unsanitary conditions include, but are not limited to, the failure to meet clarity, disinfection, pH, safety or bacteriological standards, broken glass on pool deck, electrical hazard; chemical storage.

All dry-niche light fixtures, and all underwater wet-niche light fixtures operating at more than 15 volts in public swimming pools shall be protected by a ground-fault circuit interrupter in the branch circuit, and all light fixtures in public swimming pools shall have encapsulated terminals. The ground-fault circuit interrupter shall comply with Underwriter's Laboratory standards.

36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine residual at 0.56 ppm. Stabilizer (cyanuric acid) is being utilized. Ensure that free chlorine level is between 1.5 and 10.0 ppm (since cyanuric acid is being utilized as a stabilizer). If a stabilizer is not used, ensure that chlorine level is between 1.0 and 10.0 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME GOOD NITE INN	DATE 8/4/2014	SIGNATURE
LOCATION 1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374	REHS Amanda Gaspard	

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid concentration in excess of 100 ppm.
	Not In Compliance Violation Reference - CCR - 65529	<u>Ensure that cyanuric acid concentration does not exceed 100 ppm.</u>

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed that the following signs are missing:
	Not In Compliance Violation Reference - CCR 24 - 3120B	<ol style="list-style-type: none"> 1) Sign with the name and address of the facility. 2) The telephone number of the nearest local emergency services [note: this is in addition to the 911 sign]. 3) CPR sign [note: this is in addition to the artificial respiration sign, which was provided.] 4) Diarrhea language sign. 5) Keep Gate Closed sign. <p><u>Provide signs.</u></p>

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K452 Maintenance - Flow Rate/Turnover Time

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed flow rate at 55 GPM. Required flow rate is 68 GPM.
	Not In Compliance Violation Reference - CCR 24 - 3124B	<u>Ensure to have adequate flow rate.</u>

Violation Description: The recirculation system shall have the capacity to provide a complete turnover of pool water in:

- 1. One-half hour or less for a spa pool;
 - 2. One-half hour or less for a spray ground;
 - 3. One hour or less for a wading pool;
 - 4. Two hours or less for a medical pool; and
 - 5. Six hours or less for all other types of public pools.
- The variation in flow of an operating recirculation system shall be such as not to reduce the flow below 75 percent of the rate required.

36K472 Access - Steps - Handrails - Diving Area

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed that the railings on the steps (into the pool) were loose.
	Not In Compliance Violation Reference - CCR - 3111B, 3113B	<u>Provide repairs to railing.</u>

Violation Description: Stairs shall be provided in the shallowest portion of a pool. Ladders shall be corrosion resistant and shall be equipped with slip resistant tread surfaces. Ladders shall be rigidly installed. Hand rails shall be provided at the top of both sides of each ladder and recessed steps and shall extend over the coping or edge of the deck. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.

Overall Inspection Comments

No summary comments have been made for this inspection.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME GOOD NITE INN	DATE 8/4/2014	SIGNATURE
LOCATION 1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374		REHS Amanda Gaspard

Photo Attachments:

No Photo Attachments