



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME WOODSONG APARTMENTS				DATE 8/4/2014	SIGNATURE	
LOCATION 8255 VINEYARD AV, RANCHO CUCAMONGA, CA 91730				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 5/31/2015	
MAILING ADDRESS 8255 VINEYARD AV, RANCHO CUCAMONGA CA 91730				REHS Roseann Catan		
FA # FA0006559	PR # PR0014812	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Office Spa	
TIME IN 2:00 PM	TIME OUT 2:21 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

96

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	60
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K402 Water Quality - Critical - Lack of Disinfectant

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Spa was observed with no chlorine at time of inspection. Pool operator was able to correct on site. Pool operator states, clog chlorinate.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

Overall Inspection Comments

Pool operator arrived to correct violation.

Photo Attachments:
No Photo Attachments