



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>VILLAGE AT SIERRA</b>					DATE <b>8/1/2014</b>	SIGNATURE	
LOCATION <b>8684 SIERRA AV, FONTANA, CA 92335</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>12/31/2014</b>	
MAILING ADDRESS <b>8684 SIERRA AV, FONTANA, CA 92335</b>					REHS <b>Chris Nwadike</b>		
FA # <b>FA0010977</b>	PR # <b>PR0013897</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3620</b>	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN <b>11:16 AM</b>	TIME OUT <b>12:07 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ ACTION: 01 - NO FURTHER ACTION REQUIRED		




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**96**

SCORE



temperature (F)	86.0
observed flow (gpm)	40
required flow (gpm)	73
volume (gal)	26,265
area (sq ft)	824
occupancy	41

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed cyanuric acid level at 106.00ppm. Maintain at, or below 50.00ppm. Arrange to drain, wash and refill the pool at the end of this pool season.
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR - 65529</b>	

**Violation Description:** The cyanuric acid concentration in any pool shall not exceed 100 ppm.

**36K427 Safety - Safety Signs**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed that the 'Keep Closed' sign was embedded in the 'Person with Diarrhea' sign. These are two separate signs and must be posted as separate signs clearly visible on, or from the entry gates.
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR 24 - 3120B</b>	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**  
No Photo Attachments