



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME VILLAGE AT SIERRA					DATE 8/1/2014	SIGNATURE	
LOCATION 8684 SIERRA AV, FONTANA, CA 92335					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2014	
MAILING ADDRESS 8684 SIERRA AV, FONTANA, CA 92335					REHS Chris Nwadike		
FA # FA0010977	PR # PR0013898	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa		
TIME IN 12:10 PM	TIME OUT 12:49 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	104.5
observed flow (gpm)	80
required flow (gpm)	36
volume (gal)	1,088
area (sq ft)	50
occupancy	5

36K420 Temperature - Critical - Spa Water Requirement

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed the spa water temperature at 104.5°F. Maintain the water temperature at, or below 104°F.
	Not In Compliance	
	Violation Reference - CCR 24 - 3138B	

Violation Description: The allowable water temperature of a spa pool shall not exceed 104°F.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid level at 106.00ppm. Maintain at, or below 50.00ppm. Arrange to drain, wash and refill the spa at the end of this pool season.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments