



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>CAMP METOCHE</b>					DATE <b>7/30/2014</b>	SIGNATURE	
LOCATION <b>42193 SANTA ANA RD, ANGELUS OAKS, CA 92305</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>12/31/2014</b>	
MAILING ADDRESS <b>PO BOX 345, ANGELUS OAKS CA 92305</b>					REHS <b>Robert Adams</b>		
FA # <b>FA0006888</b>	PR # <b>PR0006588</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3620</b>	PROGRAM IDENTIFIER: Pool		
TIME IN <b>1:30 PM</b>	TIME OUT <b>2:05 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**98**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	162
volume (gal)	78,030
area (sq ft)	1,292
occupancy	65

**36K418 Water Quality - Cyanurates**

POINTS <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid at greater than 100ppm. Ensure cyanuric acid is maintained at less than 100ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

**Overall Inspection Comments**

Chlorine = 1.9ppm  
 pH = 7.6  
 Cyanuric Acid = 104ppm

Photo Attachments:  
 No Photo Attachments