



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME CRAFTON HILLS COLLEGE					DATE 8/4/2014	SIGNATURE	
LOCATION 11711 SAND CANYON RD, YUCAIPA, CA 92399					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2014	
MAILING ADDRESS 11711 SAND CANYON RD, YUCAIPA CA 92399					REHS Robert Adams		
FA # FA0006242	PR # PR0028563	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool- Myrtha		
TIME IN 12:15 PM	TIME OUT 1:15 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

98

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	1,794
volume (gal)	645,750
area (sq ft)	No Data
occupancy	No Data

36K430 Safety - Equipment/First Aid Kit

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed one life ring on one side of the pool. The pool is 50 meters long by 75 feet wide. All pools that are more than 50 feet wide or 100 feet long must have one life ring and life hook on two separate side of the pool.
	Not In Compliance	
	Violation Reference - CCR - 65539	

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments