



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME LUGONIA TOWNHOMES					DATE 8/8/2014	SIGNATURE	
LOCATION 801 LUGONIA AV, REDLANDS, CA 92373					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015	
MAILING ADDRESS 5029 LA MART DRIVE, RIVERSIDE CA 92507					REHS Rick Vo		
FA # FA0008738	PR # PR0014301	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN 2:04 PM	TIME OUT 2:45 PM	CONTACT Not Captured			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE



temperature (F)	No Data
observed flow (gpm)	40
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension

CRITICAL

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC

Inspector Comments: Pool is ordered closed due to low free chlorine level. Please call 800-442-2283 for reinspection to open pool when free chlorine is at an approved level (1.5 to 10 ppm).

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K402 Water Quality - Critical - Lack of Disinfectant

CRITICAL

POINTS
4

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments: Measured free chlorine level at 0.05 ppm.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K456 Maintenance - Spa/Pool Area - Pump Room

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65535

Inspector Comments: Observed pipes leaking in pump room. Repair as needed.

Violation Description: All parts of the pool and related pool facilities and equipment shall be maintained in good repair. Floors shall be kept free from cracks and other defects. Walls, ceilings, partitions, doors and similar surfaces and equipment shall be refinished in a manner acceptable to DEHS as often as necessary to be kept in a state of good repair. Hoses shall be provided for regular flushing and cleaning. The whole pool area shall be kept clean, sanitary and free of litter and vermin.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments