



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>FERNWOOD MOBILE HOME PARK</b>					DATE <b>8/18/2014</b>	SIGNATURE	
LOCATION <b>1512 E 5TH ST, ONTARIO, CA 91764</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>6/30/2015</b>	
MAILING ADDRESS <b>1512 E 5TH ST, ONTARIO, CA 91764</b>					REHS <b>Grace Cat</b>		
FA # <b>FA0008587</b>	PR # <b>PR0014428</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	PROGRAM IDENTIFIER: Office Spa		
TIME IN <b>2:40 PM</b>	TIME OUT <b>3:14 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**92**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	102.2
observed flow (gpm)	35
required flow (gpm)	68
volume (gal)	2,060
area (sq ft)	78
occupancy	8

**36K422 Safety - Critical - Unsafe/Hazardous Conditions**



<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed gap between the housing of the light fixture and the spa shell. Repair immediately and ensure all light fixtures must permanently and secured to the shell of the spa.  Corrected on site. Operator immediately repaired the light fixture at the end of inspection.
	Not In Compliance	
Violation Reference - CCR - 116040, 65545, 116049		

**Violation Description:** Every person operating or maintaining a public swimming pool must do so in a sanitary, healthful and safe manner. Unhealthful, unsafe or unsanitary conditions include, but are not limited to, the failure to meet clarity, disinfection, pH, safety or bacteriological standards, broken glass on pool deck, electrical hazard; chemical storage.

All dry-niche light fixtures, and all underwater wet-niche light fixtures operating at more than 15 volts in public swimming pools shall be protected by a ground-fault circuit interrupter in the branch circuit, and all light fixtures in public swimming pools shall have encapsulated terminals. The ground-fault circuit interrupter shall comply with Underwriter's Laboratory standards.

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Measured the cyanuric acid level higher than 100 ppm. Maintain cyanuric acid level below 100 ppm at all times.
	Not In Compliance	
Violation Reference - CCR - 65529		

**Violation Description:** The cyanuric acid concentration in any pool shall not exceed 100 ppm.

**36K460 Skimmers - Requirements**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed missing weir gate inside the skimmer. Repair/replace.
	Not In Compliance	
Violation Reference - CCR - 65533, 3136B		

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments