



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME GOLDEN BEAR COTTAGES				DATE 8/27/2014	SIGNATURE
LOCATION 39367 BIG BEAR BL, BIG BEAR LAKE, CA 92315				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 5/31/2014
MAILING ADDRESS 830 HILLY FIELD LN, SAN BERNARDINO CA 92407				REHS Sierra Clayborn	
FA # FA0006843	PR # PR0013517	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool
TIME IN 9:39 AM	TIME OUT 10:15 AM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

96

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	76.0
observed flow (gpm)	75
required flow (gpm)	75
volume (gal)	36,000
area (sq ft)	800
occupancy	40

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine at 0.16ppm.
	Not In Compliance	Maintain free chlorine at 1.0ppm to 10ppm.
	Violation Reference - CCR - 65529	*Corrected during inspection to 5.25ppm.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments