






County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME EXECUTIVE MOBILEHOME ESTATES				DATE 9/2/2014	SIGNATURE
LOCATION 10622 BRYANT ST, YUCAIPA, CA 92399				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2014
MAILING ADDRESS 618 N EL CAMINO REAL, SAN MATEO CA 94401				REHS Robert Adams	
FA # FA0007190	PR # PR0013681	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa
TIME IN 10:50 AM	TIME OUT 11:20 AM	CONTACT Not Captured			SERVICE: 037 - POOL/SPA - BILLABLE INSPECTION SERVICE
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIR
					ACTION: 03 - REINSPECTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility



temperature (F) | No Data
 observed flow (gpm) | No Data
 required flow (gpm) | No Data
 volume (gal) | No Data
 area (sq ft) | No Data
 occupancy | No Data

36K404 Water Quality - Critical - High Disinfectant Level ⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Chlorine still over 10.0 ppm Spa still closed.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K406 Water Quality - Critical - pH High/Low ⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: pH observed at 6.8. Spa still closed.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments