



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME YMCA OF REDLANDS				DATE 9/5/2014	SIGNATURE <i>Jay Brown</i>
LOCATION 500 E CITRUS AV, REDLANDS, CA 92373				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2014
MAILING ADDRESS 500 E CITRUS AV, REDLANDS CA 92373				REHS Rick Vo	
FA # FA0008702	PR # PR0015769	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Indoor - Large Pool
TIME IN 9:03 AM	TIME OUT 9:35 AM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	425
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K406 Water Quality - Critical - pH High/Low

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Measured pH at 7.1.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Obtain approved test kit. Operator test kit can only measure up to 5ppm free chlorine.
	Not In Compliance	
	Violation Reference - CCR - 65523, 65529	

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

Overall Inspection Comments

jbrown@ymcaeastvalley.org
 Jay Brown
 Facilities Director
 909-712-8657

Photo Attachments:
 No Photo Attachments