



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME YMCA OF REDLANDS				DATE 9/5/2014	SIGNATURE	
LOCATION 500 E CITRUS AV, REDLANDS, CA 92373				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 3/31/2015	
MAILING ADDRESS 500 E CITRUS AV, REDLANDS CA 92373				REHS Rick Vo		
FA # FA0008702	PR # PR0033494	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Hydrotherapy Spa	
TIME IN 10:06 AM	TIME OUT 10:35 AM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

98

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	102.0
observed flow (gpm)	150
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Operator test kit can only read up to 5ppm. Obtain an approved test kit that can read up to at least 10ppm free chlorine.
	Not In Compliance	
	Violation Reference - CCR - 65523, 65529	

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments