



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>SLEEPY HOLLOW CABINS &amp; MOTEL</b>					DATE <b>9/8/2014</b>	SIGNATURE	
LOCATION <b>24033 LAKE DR, CRESTLINE, CA 92325</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>2/28/2015</b>	
MAILING ADDRESS <b>PO BOX 632, CRESTLINE CA 92325</b>					REHS <b>Dior Porter</b>		
FA # <b>FA0006805</b>	PR # <b>PR0015343</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	PROGRAM IDENTIFIER: Spa		
TIME IN <b>2:49 PM</b>	TIME OUT <b>3:01 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**98**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Flow meter stuck. Repair the flow meter so that the flow rate may be determined.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**Overall Inspection Comments**

Note: chlorine and pH values have been omitted due to the fact that the spa is not in operation after labor day. Please keep in mind when the pool is in operation pH shall be 7.2-8.0 and chlorine 1.5-10ppm. Thank you!

**Photo Attachments:**  
No Photo Attachments