



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME VILLAGE BAY CHALETS				DATE 9/9/2014	SIGNATURE
LOCATION 28050 HWY 189 , LAKE ARROWHEAD, CA 92352				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2014
MAILING ADDRESS PO BOX 890 , RANCHO CUCAMONGA CA 91729-0890				REHS Dior Porter	
FA # FA0006816	PR # PR0014787	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa
TIME IN 1:20 PM	TIME OUT 1:30 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED




RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

96

SCORE



temperature (F)	90.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Permit suspended due to high amount of chlorine. Measured above 10ppm chlorine. Provide 1.5-10ppm chlorine. Contact the program of Environmental Health at 800-442-2283 for reinspection once the correction has been made.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Measured above 10ppm chlorine. Provide 1.5-10ppm chlorine.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments