



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**



(800) 442-2283

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

FACILITY NAME <b>CAL STATE UNIVERSITY</b>				DATE <b>9/11/2014</b>	SIGNATURE	
LOCATION <b>5500 UNIVERSITY PKWY, SAN BERNARDINO, CA 92407</b>				REINSPECTION DATE <b>2/11/2015</b>	PERMIT EXPIRATION	
MAILING ADDRESS <b>5500 UNIVERSITY PKWY, SAN BERNARDINO CA 92407</b>				REHS <b>Dior Porter</b>		
FA # <b>FA0006500</b>	PR # <b>PR0014827</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3603</b>	PROGRAM IDENTIFIER: Dorm Pool	
TIME IN <b>10:26 AM</b>	TIME OUT <b>10:42 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
					ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPENED	

**RECREATIONAL HEALTH - Public School Pool / Spa**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	83
volume (gal)	29,920
area (sq ft)	No Data
occupancy	50

**36K992 Permit Reinstatement**

POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed 4ppm chlorine and pH of 7.4. Thank you! Permit reinstated.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** The health permit to operate is hereby reinstated and facility may open.

**36K994 Reinspection**

POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Reinspection to determine compliance for chlorine and pH levels. Observed 4ppm chlorine and pH of 7.4. Thank you!
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

Note: Pool surrounded with caution tape upon arrival. Thank you for taking additional measures to secure the pool until it was reinspected.

**Photo Attachments:**

No Photo Attachments