



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME LAKE ARROWHEAD COUNTRY CLUB					DATE 9/15/2014	SIGNATURE	
LOCATION 250 GOLF COURSE RD, LAKE ARROWHEAD, CA 92352					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2014	
MAILING ADDRESS PO BOX 670, LAKE ARROWHEAD CA 92352					REHS Dior Porter		
FA # FA0007771	PR # PR0013888	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool		
TIME IN 10:32 AM	TIME OUT 11:30 AM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		



RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE



temperature (F)	No Data
observed flow (gpm)	300
required flow (gpm)	166
volume (gal)	80,000
area (sq ft)	No Data
occupancy	90

36K438 Enclosure - Critical - Gates Drowning Hazard



POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed gate near men's restroom incapable of fully self closing. (gate is not high enough to clear the concrete) Properly repair the gate so that it self closes and self latches. Operator locked the gate.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed.

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Missing facility name and address in one inch lettering. Post the required information on a sign in the pool area.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments