



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME VILLA GABRIEL HOA				DATE 9/19/2014	SIGNATURE	
LOCATION 8300 GABRIEL DR, RANCHO CUCAMONGA, CA 91730				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2014	
MAILING ADDRESS PO BOX 5022, UPLAND CA 91785				<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Grace Cat		
FA # FA0004427	PR # PR0015418	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool	
TIME IN 12:40 PM	TIME OUT 1:07 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

98

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	90
required flow (gpm)	80
volume (gal)	29,000
area (sq ft)	940
occupancy	42

36K456 Maintenance - Spa/Pool Area - Pump Room

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed standing water inside the pump room. Clean and maintain the pump room on a regular basis.
	Not In Compliance	
	Violation Reference - CCR - 65535	

Violation Description: All parts of the pool and related pool facilities and equipment shall be maintained in good repair. Floors shall be kept free from cracks and other defects. Walls, ceilings, partitions, doors and similar surfaces and equipment shall be refinished in a manner acceptable to DEHS as often as necessary to be kept in a state of good repair. Hoses shall be provided for regular flushing and cleaning. The whole pool area shall be kept clean, sanitary and free of litter and vermin.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments