



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>WATERBROOK APARTMENTS</b>				DATE <b>9/23/2014</b>	SIGNATURE	
LOCATION <b>10400 ARROWHEAD , RANCHO CUCAMONGA, CA 91730</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION	
MAILING ADDRESS <input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT <b>1270 SUNSHINE WAY ANAHEIM, CA 92506</b>				REHS <b>Bennetta Betbadal</b>		
FA # <b>FA0005612</b>	PR # <b>Not Specified</b>	SR # <b>SR0065387</b>	CO # <b>Not Specified</b>	PE <b>3716</b>	PROGRAM IDENTIFIER: <b>None</b>	
TIME IN <b>11:00 AM</b>	TIME OUT <b>11:30 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>025 - PLAN REVIEW</b>	
					RESULT: <b>01 - CORRECTIVE ACTION NOT REQUIRED</b>	
					ACTION: <b>55 - PLANS APPROVED</b>	

**RECREATIONAL HEALTH PLAN CHECK - PInCk Pool Minor Remodel - all**

**37K980 Plans - Plan Review Approved**

**Compliance Date:** Not Specified

**Inspector Comments:** Plan is approved for minor remodel of the pool and spa #2 (fitness center-south).

**Not In Compliance**

**Violation Reference - HSC**

Scope of work consist of replaster, new waterline tiles, depth markers and trim tiles, new coping for the spa.

**Violation Description:** Plans have been approved and this correction sheet is a part of the approved plans.

**Overall Inspection Comments**

Ensure to install depth makers and no diving signs on the deck for the pool and depth makers on the deck for the spa.

Ensure for final all safety signs are updated. Pool and spa lights are working.

**Photo Attachments:**

No Photo Attachments