



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT


www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME WATERMAN APARTMENTS				DATE 9/23/2014	SIGNATURE
LOCATION 2634 COPPER LN, SAN BERNARDINO, CA 92408				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 5/31/2015
MAILING ADDRESS 2634 COPPER LN, SAN BERNARDINO, CA 92408				REHS Amanda Gaspard	
FA # FA0012062	PR # PR0013525	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool
TIME IN 11:05 AM	TIME OUT 11:30 AM	CONTACT Not Captured			SERVICE: 037 - POOL/SPA - BILLABLE INSPECTION SERVICE
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPENED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Pool is re-opened. Permit is reinstated.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: The health permit to operate is hereby reinstated and facility may open.

36K993 Re-Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: During the routine inspection on 07-14-14, pool was closed due to high free chlorine levels. During the re-inspection on 07-31-14, observed pH at 7.1 and free chlorine level in excess of 11.0 ppm. Pool remained closed. Facility requested a re-inspection. During the re-inspection on 08-12-14, observed pH at 7.3 and free chlorine level in excess of 11.0 ppm. Pool remained closed, due to high free chlorine levels. Facility requested a re-inspection. During the billable re-re-re-inspection on 08-21-14, observed pH at 7.1 and free chlorine levels at 11.5 ppm. Facility has requested a re-inspection. During the billable re-re-re-re-inspection on 09-23-14, observed pH at 7.4 and free chlorine at 5.22 ppm. Pool is re-opened. Permit is reinstated.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Billable re-reinspection conducted at the time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments