



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>FERNROCK ESTATES</b>				DATE <b>9/11/2014</b>	SIGNATURE
LOCATION <b>872 SIERRA VISTA DR, TWIN PEAKS, CA 92391</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>5/31/2015</b>
MAILING ADDRESS <b>1420 N CLAREMONT BL STE 205-D, CLAREMONT CA 91711</b>				REHS <b>Dior Porter</b>	
FA # <b>FA0001438</b>	PR # <b>PR0015696</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3620</b>	PROGRAM IDENTIFIER: Pool
TIME IN <b>3:42 PM</b>	TIME OUT <b>4:20 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 01 - NO FURTHER ACTION REQUIRED




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**98**

SCORE



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K444 Equipment - Recirculation Pump/Filter/Separation Tank**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b>
	Not In Compliance	
Violation Reference - HSC - 3120B, 3132B, 3141B		

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

**Overall Inspection Comments**

Unable to access recirculation equipment. Provide a set of keys to Environmental Health located at 385 N. Arrowhead Ave. , San Bernardino CA 92415.

**Photo Attachments:**  
No Photo Attachments