



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME ALPINE CAMP AND CONFERENCE CENTER				DATE 10/1/2014	SIGNATURE
LOCATION 415 CLUBHOUSE DR, BLUE JAY, CA 92317				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2014
MAILING ADDRESS PO BOX 155, BLUE JAY CA 92317				REHS Dior Porter	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: Pool	
FA # FA0006940	PR # PR0006509	SR # Not Specified	CO # Not Specified	PE 3620	SERVICE: 001 - INSPECTION - ROUTINE
TIME IN 12:30 PM	TIME OUT 1:00 PM	CONTACT Not Captured			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 01 - NO FURTHER ACTION REQUIRED



RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

100
SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

No Violations Cited

Overall Inspection Comments

Pool not in use for the rest of the season. Please ensure that chlorine is maintained at 1.5-10ppm and the pH at 7.2-8. Recirculation system was on and functioning. Observed secure physical structures and pool water clear. Required signs were posted and the recirculation system was labeled. Thank you.

Photo Attachments:

No Photo Attachments