



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT



www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME DESERT VISTA VILLAGE				DATE 10/9/2014	SIGNATURE <i>Ruth... + 1 of 10</i>
LOCATION 7345 PALM AV, YUCCA VALLEY, CA 92284				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
MAILING ADDRESS PO BOX 90250, HENDERSON NV 89009				REHS Marilyn Krichbaum	
FA # FA0017228	PR # PR0023257	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool
TIME IN 10:20 AM	TIME OUT 10:35 AM	CONTACT Not Captured			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPENED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Reinspection. Observed a chlorine level of 2.8, ph level of 7.3. Pool can be reopened. Replace the nonfunctioning flowmeter. Identify the filters. Label the flow of the water thru the recirculation system on the pool piping by using arrows.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments