



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME COUNTRY INN & SUITES					DATE 10/10/2014	SIGNATURE	
LOCATION 4674 E ONTARIO MILLS PKWY, ONTARIO, CA 91761					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 11/30/2014	
MAILING ADDRESS 4674 E ONTARIO MILLS PKWY, ONTARIO CA 91764					REHS Sumedha Singh		
FA # FA0016685	PR # PR0022270	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa		
TIME IN 9:01 AM	TIME OUT 9:41 AM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		




RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE



temperature (F)	101.2
observed flow (gpm)	80
required flow (gpm)	43
volume (gal)	1,312
area (sq ft)	70
occupancy	7

36K414 Water Quality - Non-Critical - pH High/Low

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed pH below 7.0 during the initial testing. Maintenance was able to make the proper adjustments during the inspection. pH was adjusted to 7.2.
	Complied on 10/10/2014	
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid concentration in excess of 100 ppm. Ensure that cyanuric acid concentration does not exceed 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no sign for the local emergency phone number or site address. Provide a sign for the site address and the local emergency phone number (separate from the 911 number) within the pool/spa area.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME COUNTRY INN & SUITES	DATE 10/10/2014	SIGNATURE
LOCATION 4674 E ONTARIO MILLS PKWY, ONTARIO, CA 91761	REHS Sumedha Singh	

One tree were observed outside of the pool and spa that have become thicker through the years. At this time it is recommended that the trees be cut down or removed at least 5 feet away from the fencing to not allow ease of climbing to gain access to the pool/spa area. This could become a violation in the future and be required to be removed.

Photo Attachments:

No Photo Attachments