



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>NOVA POINTE</b>				DATE <b>12/17/2014</b>	SIGNATURE	
LOCATION <b>800 E WASHINGTON , COLTON, CA 92324</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION	
MAILING ADDRESS <b>2566 OVERLAND AV STE 700 LOS ANGELES, CA 90064</b>				REHS <b>Bennetta Betbadal</b>		
FA # <b>FA0006153</b>	PR # <b>Not Specified</b>	SR # <b>SR0066452</b>	CO # <b>Not Specified</b>	PE <b>3716</b>	PROGRAM IDENTIFIER: <b>None</b>	
TIME IN <b>3:30 PM</b>	TIME OUT <b>3:50 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>025 - PLAN REVIEW</b>	
				RESULT: <b>01 - CORRECTIVE ACTION NOT REQUIRED</b>		
				ACTION: <b>55 - PLANS APPROVED</b>		

**RECREATIONAL HEALTH PLAN CHECK - Plnck Pool Minor Remodel - all**

**37K980 Plans - Plan Review Approved**

**Compliance Date:** Not Specified

**Not In Compliance**

**Violation Reference** - HSC

**Inspector Comments:**

Plan is approved for installation of an integrated UMA Solar SunStar heating system. NE POOL

Existing pump will be used with 3-way valve with actuator.

**Violation Description:** Plans have been approved and this correction sheet is a part of the approved plans.

**Overall Inspection Comments**

Pool Capacity: 22,000 gallons  
Turn Over Rate: 46-61 gpm  
Pump: Pentair Wishperflo WFE-4 1HP with 76 gpm.

3139B.1 The installation of a solar heating system on a new or existing pool shall not interfere with the required turnover rate as specified in Section 3124B nor exceed the pipe flow velocities as specified in Section 3125B.1.  
Call for final inspection one week in advance.

**Photo Attachments:**

No Photo Attachments