



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**



[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>HILLCREST MOBILE ESTATES</b>					DATE <b>12/18/2014</b>	SIGNATURE <i>Robert Adams</i>	
LOCATION <b>33600 CALIMESA BL, YUCAIPA, CA 92399</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>12/31/2014</b>	
MAILING ADDRESS <b>33600 CALIMESA BL, YUCAIPA, CA 92399</b>					REHS <b>Robert Adams</b>		
FA # <b>FA0007160</b>	PR # <b>PR0014724</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	PROGRAM IDENTIFIER: Spa SERVICE: 037 - POOL/SPA - BILLABLE INSPECTION SERVICE		
TIME IN <b>3:48 PM</b>	TIME OUT <b>4:08 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED ACTION: 01 - NO FURTHER ACTION REQUIRED		

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	10
volume (gal)	5,000
area (sq ft)	160
occupancy	8

**36K993 Re-Reinspection**

<b>POINTS</b>	Compliance Date: Not Specified
<b>NA</b>	Not In Compliance
	Violation Reference - HSC

**Inspector Comments:** Observed compliance with corrections noted on the inspection from December 3rd, 2014. A functioning deck valve was installed to control the flow between the skimmer and main drain. The valve gives at least 100% of suction capability to the skimmer. Observed sump constructed properly.

The spa is VGB protected with one main drain cover for the filtration and booster suction line with a 361GPM capable drain cover and SVRS pumps. (Cover = Aquastar WAV12WR101)

Operator provided two VGB AB 1020 Compliance forms (One for each pump in the spa). The forms were filled out by a licensed contractor State license # 847612.

These forms will be submitted to the district supervisor (J Krygier) on Friday 12-19-14. And placed in EC for retention.

**Violation Description:** Billable re-reinspection conducted at the time to determine compliance from prior inspection.

**Overall Inspection Comments**

Ensure spa is filled to the appropriate level and chemicals are tested and adjusted prior to allowing swimmers in the spa. For questions on how to maintain your spa, please contact 1-800-442-2283 and ask to speak to your district inspector.

**Photo Attachments:**

No Photo Attachments