



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME UPLAND VISTA				DATE 12/26/2014	SIGNATURE	
LOCATION 1532 CORTE HACIENDA , UPLAND, CA 91786					REINSPECTION DATE Not Specified	PERMIT EXPIRATION
MAILING ADDRESS 1547 LOS ANGELES AVE VENTURA, CA 93004				REHS Robert Adams		
FA # FA0008524	PR # Not Specified	SR # SR0066243	CO # Not Specified	PE 3716	PROGRAM IDENTIFIER: None	
TIME IN 10:40 AM	TIME OUT 11:35 AM	CONTACT Not Captured			SERVICE: 126 - PLAN CHECK FIELD INSPECTION	
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH PLAN CHECK - Plnck Pool Minor Remodel - all

37K985 Plans - Final Inspection

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: Facility inspection conducted this date.

Facility approved to open pending corrections.

- 1) Install deck drain covers.
- 2) Install back flow prevention device on the hose bib closest to the restrooms on the deck.
- 3) Install flow meter on the return line of the pool. I

Violation Description: Final inspection hereby gives facility approvals to open pending the listed violations are corrected as specified. Failure to complete corrections may result in legal action.

Overall Inspection Comments

Upland Vista - Final

Photo Attachments:
No Photo Attachments