



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME NOVA POINTE				DATE 1/7/2015	SIGNATURE	
LOCATION 800 E WASHINGTON , COLTON, CA 92324				REINSPECTION DATE Not Specified	PERMIT EXPIRATION	
MAILING ADDRESS 2566 OVERLAND AV STE 700 LOS ANGELES, CA 90064				REHS Robert Adams		
FA # FA0006153	PR # Not Specified	SR # SR0066452	CO # Not Specified	PE 3716	PROGRAM IDENTIFIER: None	
TIME IN 1:10 PM	TIME OUT 1:34 PM	CONTACT Not Captured			SERVICE: 126 - PLAN CHECK FIELD INSPECTION	
				RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIR		
				ACTION: 03 - REINSPECTION REQUIRED		

RECREATIONAL HEALTH PLAN CHECK - Plnck Pool Minor Remodel - all

37K510 Plans - Preliminary Inspection

Compliance Date: Not Specified

Not In Compliance

Violation Reference - Reference Number - SBC Policy

Inspector Comments: Preliminary inspection conducted this date for the installation of a solar water heating device.

The pool was built in 1984 and is subject to a 6 hour turn over rate with a required flow of 61GPM.

The minimum flow rate was not achieved. (58GPM)

Contractor stated he would be coming up with a proposal to achieve the flow rate.

If the solution includes the installation of a booster pump, please consult with Robert Adams prior to installation.

Once proposed solution is approved complete the installation and call for reinspection.

Violation Description: Preliminary inspection

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments