



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME NOVA POINTE				DATE 1/7/2015	SIGNATURE	
LOCATION 800 E WASHINGTON , COLTON, CA 92324				REINSPECTION DATE Not Specified	PERMIT EXPIRATION	
MAILING ADDRESS 2566 OVERLAND AV STE 700 LOS ANGELES, CA 90064				REHS Robert Adams		
FA # FA0006153	PR # Not Specified	SR # SR0066450	CO # Not Specified	PE 3716	PROGRAM IDENTIFIER: None	
TIME IN 1:35 PM	TIME OUT 1:50 PM	CONTACT Not Captured			SERVICE: 126 - PLAN CHECK FIELD INSPECTION	
				RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIR		
				ACTION: 03 - REINSPECTION REQUIRED		

RECREATIONAL HEALTH PLAN CHECK - PInCk Pool Minor Remodel - all

37K510 Plans - Preliminary Inspection

Compliance Date: Not Specified

Not In Compliance

Violation Reference - Reference Number - SBC Policy

Inspector Comments: Preliminary inspection conducted this date for the installation of a solar water heating device on the Northwest Pool.(#2)

The pool was built in 1984 and is subject to a 6 hour turn over rate with a required flow of 83GPM.

The minimum flow rate was not able to be verified as the flow meter was installed prior to the solar device loop.

Install a flow meter after the solar system to determine if the flow needed for proper turn over is achieved when the system is running.

Violation Description: Preliminary inspection

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments