



**Public Health**  
Environmental Health Services




www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>HAMPTON INN &amp; SUITES</b>		DATE <b>7/7/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>4/30/2016</b>
LOCATION <b>250 N 9TH ST, COLTON, CA 92324</b>			INSPECTOR <b>James Gutman</b>	
MAILING ADDRESS <b>105 DECKER CT STE 500, IRVING TX 75062</b>			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 153 - RESPONSE TO POOL SURVEY	
TIME IN <b>3:20 PM</b>	TIME OUT <b>3:25 PM</b>	FACILITY ID <b>FA0008659</b>	RELATED ID <b>PR0014087</b>	PE <b>3620</b>
RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU				
ACTION: 13 - PERMIT SUSPENDE / FACILITY CLOSED				

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	40
volume (gal)	No Data
area (sq ft)	No Data
occupancy	20

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**No Violations Cited**

**Overall Inspection Comments**

During a safety survey, the pool aide from Environmental Health Services (EHS) found the clarity in the pool to be poor. They were unable to clearly see the bottom of the pool. The pool was posted closed, not to be used, for this safety hazard. Please call your inspector at 800-442-2283 for an inspection prior to reopening your pool. Do not reopen your pool for service without approval from EHS.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0