



Public Health
Environmental Health Services


www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME EAGLE RIDGE APTS		DATE 7/8/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 2/28/2016
LOCATION 1315 S MEADOW LN, COLTON, CA 92324			INSPECTOR James Gutman	
MAILING ADDRESS 1315 S MEADOW LANE, COLTON CA 92324			IDENTIFIER: Office Spa	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 153 - RESPONSE TO POOL SURVEY	
TIME IN 4:10 PM	TIME OUT 4:15 PM	FACILITY ID FA0008670	RELATED ID PR0013666	PE 3623
RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQ				
ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED				

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	6

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

No Violations Cited

Overall Inspection Comments

During a safety survey, the pool aide from Environmental Health Services (EHS) found the main drain cover in the pool to be in poor condition. The cover was broken which could lead to a suction hazard or entrapment. The pool was posted closed, not to be used, for this safety hazard. Please call your inspector at 800-442-2283 for an inspection prior to reopening your pool. Do not reopen your pool for service without approval from EHS.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0