





RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME RAMADA INN		DATE 9/8/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2015
LOCATION 1511 E MAIN ST, BARSTOW, CA 92311			INSPECTOR Jim Nichol	
MAILING ADDRESS 1511 E MAIN ST, BARSTOW CA 92311			IDENTIFIER: Spa	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 153 - RESPONSE TO POOL SURVEY	
TIME IN 2:15 PM	TIME OUT 2:20 PM	FACILITY ID FA0006202	RELATED ID PR0014854	PE 3623
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 13 - PERMIT SUSPENDE / FACILITY CLOSED	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	27
volume (gal)	1,700
area (sq ft)	86
occupancy	8

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

No Violations Cited

Overall Inspection Comments

SPA BOTTOM DRAIN SUCTION HAZARD

During a safety survey, the pool aide from Environmental Health Services (EHS) found the bottom drain cover in the spa to be in poor condition. The cover was missing/broken which could lead to a suction hazard or entrapment. The spa was posted closed, not to be used, for this safety hazard. Please call your inspector at 800-442-2283 for an inspection prior to reopening your pool. Do not reopen your pool for service without approval from EHS.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0