



**RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REPORT**

FACILITY NAME 9743 WOO		REINSPECTION DATE Not Specified		INSPECTOR Jane Troy	DATE 4/1/2016
LOCATION 9743 WOODLEAF, RANCHO CUCAMONGA, CA 91730				PERMIT EXPIRATION	IDENTIFIER: None
TIME IN 11:40 AM	TIME OUT 12:10 PM	FACILITY ID FA0006818	RELATED ID SR0071073	PE 3711	SERVICE: 126 - PLAN CHECK FIELD INSPECTION RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED

**RECREATIONAL HEALTH PLAN CHECK - Plnck Pool Major Remodel 0-999 SqFt**

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**37K241 Safety - Equipment**

**Compliance Date:** Not Specified  
**Not In Compliance**  
**Reference - CCR 22 - 65539**

**Inspector Comments:** Attach missing throw rope to the existing life ring and hang poolside along with body hook for safety.

**Description:** Supply the following safety equipment: 1) Body hook on a 12 foot pole. 2) Life ring, with attached throw rope of 3/16 inch diameter, long enough to span the maximum width of the pool.

**37K300 Water Quality - Chlorine**

**Compliance Date:** Not Specified  
**Not In Compliance**  
**Reference - CCR 22 - 65529 (a)**

**Inspector Comments:** Pool water was tested today for chlorine residual. Pool was reading .03 ppm and spa .17 ppm. Maintain a free chlorine residual of 1.5 ppm when using stabilized chlorine tablets.

**Description:** Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).

**37K509 Plans - Final Inspection**

**Compliance Date:** Not Specified  
**Not In Compliance**  
**Reference - Reference Number - SBC Policy**

**Inspector Comments:** Final inspection conducted today for pool & spa remodel. Scope of the remodel consisted of new decking, coping, handrails, tile & depth markers for pool and new decking, coping, tile, depth markers, drain covers and replaster for spa.

All construction has been completed in accordance with approved plans and meets current health code requirements.

OK to reopen pool and spa for use upon compliance with the following violation:

**Description:** Final inspection hereby gives facility approvals to open.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:  
Total # of Images: 0