



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LIFESTYLE APARTMENTS		REINSPECTION DATE Not Specified		INSPECTOR Jessica Smith	DATE 5/6/2016
LOCATION 16324 MERRILL AV, FONTANA, CA 92335				PERMIT EXPIRATION 9/30/2016	IDENTIFIER: Pool
TIME IN 11:15 AM	TIME OUT 11:45 AM	FACILITY ID FA0006522	RELATED ID PR0013587	PE 3620	SERVICE: 001 - INSPECTION - ROUTINE RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

98
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	40
required flow (gpm)	56
volume (gal)	20,266
area (sq ft)	648
occupancy	32

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K527 Safety – Safety signs

POINTS 1	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3120B	Inspector Comments: Provide the following sign(s): (a) "Keep Gate Closed" on exterior of pool enclosure gate in 4 inch lettering; (b) The phone number of the nearest emergency services in 1 inch text; (c) The name and address of pool facility in 1 inch lettering; (d) "Persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not enter water" in 1 inch letters.
---------------------------	--	--

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K554 Equipment - Pressure/Vacuum gauge requirements

POINTS 1	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR 24 - 3125B.2	Inspector Comments: Provide vacuum gauge for pool equipment. Observed to be missing.
---------------------------	---	---

Violation Description: A pressure and vacuum gauge shall be provided for each pump system. Each gauge shall have a scale range approximately 1 1/4 times the maximum anticipated working pressure or vacuum and shall be accurate within 2 percent of scale. The pressure gauge located on the filter shall be marked with the clean start up pressure reading.



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LIFESTYLE APARTMENTS	DATE 5/6/2016
LOCATION 16324 MERRILL AV, FONTANA, CA 92335	INSPECTOR Jessica Smith

Overall Inspection Comments

pH=7.8
 Combined chlorine=0ppm
 Free chlorine=4.39ppm
 Cyanuric acid concentration=21
 Flow meter: 40 rpm
 Pressure gauge: 12psi
 Vacuum gauge: missing

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0