



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**



FACILITY NAME <b>DEL ROSA ISLE APARTMENTS</b>				REINSPECTION <b>Not Specified</b>	INSPECTOR <b>Leilah Kelsey</b>	DATE <b>7/26/2016</b>
LOCATION <b>6252 DEL ROSA AV, SAN BERNARDINO, CA 92404</b>				PERMIT <b>2/28/2017</b>	IDENTIFIER: Pool	
TIME IN <b>3:42 PM</b>	TIME OUT <b>3:47 PM</b>	FACILITY ID <b>FA0007305</b>	RELATED ID <b>PR0015964</b>	PE <b>3620</b>	SERVICE: 153 - RESPONSE TO POOL SURVEY	
				RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED		
				ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your

**36K995 Permit - Suspension**



**POINTS**  
**NA**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC

**Inspector Comments:** During a safety survey, the pool aide from Environmental Health Services (EHS) found the clarity in the pool to be poor. They were unable to clearly see the bottom of the pool. The pool was posted closed, not to be used, for this safety hazard. Please call your inspector at 800-442-2283 for an inspection prior to reopening your pool. Do not reopen your pool for service without approval from EHS.

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0