



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME FOUR SEASONS		REINSPECTION DATE Not Specified		INSPECTOR William Kirschman	DATE 8/18/2016
LOCATION 1419 RIALTO AV, COLTON, CA 92324				PERMIT EXPIRATION 7/31/2017	IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE
TIME IN 11:40 AM	TIME OUT 12:10 PM	FACILITY ID FA0002629	RELATED ID PR0015561	PE 3620	RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

99
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K552 Equipment - Flow meter provided

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed that flow meter is stuck. Repair or replace flow meter.
	Not In Compliance	
	Violation Reference - CCR 24 - 3125B.3	

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow and installed according to the manufacturer's written instructions with increments in the range of normal flow.

Overall Inspection Comments

- Free chlorine @ 5.7 ppm - ok
- CYA @ 63 ppm - ok
- pH @ 7.5 - ok
- Water clarity good
- Safety equipment - ok
- Fence and gate - ok
- Safety signs - ok
- Drain covers - ok
- Equipment room - ok

Signature(s) of Acknowledgement

NAME:
TITLE:



Public Health
Environmental Health Services

www.SBCounty.gov
www.SBCounty.gov/dph/dehs

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME FOUR SEASONS	DATE 8/18/2016
LOCATION 1419 RIALTO AV, COLTON, CA 92324	INSPECTOR William Kirschman

Total # of Images: 0