



Public Health

Environmental Health Services

RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

FACILITY NAME FOOD4LESS		DATE 7/29/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION
LOCATION 1150 N PEPPER AV, COLTON, CA 92324			INSPECTOR Robert Adams	
MAILING ADDRESS 111 W OCEAM BLVD 21ST FLOOR LONG BEACH, CA 90802			IDENTIFIER: None	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 126 - PLAN CHECK FIELD INSPECTION	
TIME IN 12:10 PM	TIME OUT 12:38 PM	FACILITY ID FA0011045	RELATED ID SR0067405	PE 1787
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 03 - REINSPECTION REQUIRED	

RETAIL FOOD PLAN CHECK - PInCk FHP Minor 20,000-Up SqFt

17K832 Plans - Preliminary Inspection

Compliance Date: Not Specified

Inspector Comments: Preliminary inspection conducted this date. No corrections noted. One remaining item to finish. See report. Follow up schedule for Weds Aug 5, 2015.

Not In Compliance

Reference - Reference Number - SBC Policy

Description: Preliminary inspection.

17K057 Equipment - Construction - Walls

Compliance Date: Not Specified

Inspector Comments: Flash the proofer.

Not In Compliance

Reference - CCDEH Guidelines - CCDEH

Description: The cooking equipment must be spaced six (6) inches apart and from adjacent walls, or flashed together and to the walls, or, the cooking equipment must be equipped with commercial castors and quick disconnect gas lines.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:

TITLE:

Total # of Images: 0