



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>ARROWPARK APTS</b>		REINSPECTION DATE <b>Not Specified</b>		INSPECTOR <b>Helen Godinez</b>	DATE <b>6/3/2016</b>
LOCATION <b>17450 ARROW BL, FONTANA, CA 92335</b>				PERMIT EXPIRATION <b>10/31/2016</b>	
TIME IN <b>9:15 AM</b>	TIME OUT <b>9:31 AM</b>	FACILITY ID <b>FA0003995</b>	RELATED ID <b>PR0015849</b>	IDENTIFIER: Pool SERVICE: 006 - FIELD CONSULTATION RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 03 - REINSPECTION REQUIRED	
		PE <b>3620</b>			




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	40
volume (gal)	14,400
area (sq ft)	480
occupancy	20

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K546 Equipment – Non-Critical - Water treatment system operation**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed an unattached DE filter in the corner of the pump room and a newer cartridge filter attached to the recirculation system. Operator did not know if Environmental Health Division- Plan Check was advised of the change.
	Violation Reference - HSC - 65525	
Ensure to submit plans to the Environmental Health Division-Plan Check anytime a change is made to the pool facility, spa facility and recirculation equipment.		

**Violation Description:** The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].

**Overall Inspection Comments**

Submit three (3) set of plans, for changes made to the recirculation system, to the Environmental Health Division- Plan Check.  
Submit with fees on or before June 29, 2016 to:

Department of Public Health  
Division of Environmental Health  
172 W 3rd Street  
San Bernardino, CA 92415  
1-800-442-2283

**Signature(s) of Acknowledgement**

*NSA*

NAME: no signature available  
TITLE:



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME ARROWPARK APTS	DATE 6/3/2016
LOCATION 17450 ARROW BL, FONTANA, CA 92335	INSPECTOR Helen Godinez

Total # of Images: 0