



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SUN CHASE COMM POOL & SPA		DATE 4/15/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 9/30/2015
LOCATION 31027 MOSS ST, MENTONE, CA 92359			INSPECTOR Tia Wilson	
MAILING ADDRESS 9231 ARCHIBALD AV, RANCHO CUCAMONGA CA 91730			IDENTIFIER: Pool	
TIME IN 9:16 AM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 9:45 AM			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQ	
FACILITY ID FA0005105			ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	
RELATED ID PR0015158			PE 3620	




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

88
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	68
volume (gal)	24,480
area (sq ft)	816
occupancy	12

36K406 Water Quality - Critical - pH High/Low ⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed pH measuring 6.9. Raise pH to between 7.2 and 8.0.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid measuring above 100 ppm. Adjust cyanuric acid levels to less than 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed recirculation system missing arrows to indicate direction of flow. Provide markings indicating direction of flow on recirculation piping.
	Not In Compliance	
	Violation Reference - HSC - 3120B, 3132B, 3141B	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed flowmeter not functioning. Replace flowmeter.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SUN CHASE COMM POOL & SPA	DATE 4/15/2015
LOCATION 31027 MOSS ST, MENTONE, CA 92359	INSPECTOR Tia Wilson

36K458 Maintenance - Test Kit/Daily Records

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed daily log not available. Provide documentation on premises.
	Not In Compliance	
	Violation Reference - CCR - 65523, 65529	

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

Overall Inspection Comments

Measured observations:

pH 6.9

Free Chlorine 3.81 ppm

Cyanuric Acid "HI" reading, indicating concentration above 100 ppm.

Pool closed due to low pH and must remain closed until compliance is verified. Call 1-800-442-2283 after corrective actions have been made for reinspection.

Signature(s) of Acknowledgement

A handwritten signature in blue ink that reads "Robert Schweigo".

NAME: Robert Schweigo
 TITLE: Maintenance Employee

Total # of Images: 0