



Public Health

Environmental Health Services

www.SBCounty.gov

RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

| | | | | |
|---|---------------------|--------------------------|---|-------------------|
| FACILITY NAME FONTANA PHO RESTAURANT | | DATE 6/16/2015 | REINSPECTION DATE 6/16/2015 | PERMIT EXPIRATION |
| LOCATION 9820 SIERRA B/C, FONTANA, CA 91730 | | | INSPECTOR Sumedha Singh | |
| MAILING ADDRESS 1711 MAGELLAN ST WEST COVINA, CA 91791 | | | IDENTIFIER: None | |
| | | | SERVICE: 025 - PLAN REVIEW | |
| TIME IN 1:16 PM | TIME OUT 2:59 PM | FACILITY ID FA0009731 | RELATED ID SR0068635 | PE 1767 |
| | | | RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED | |
| | | | ACTION: 55 - PLANS APPROVED | |

RETAIL FOOD PLAN CHECK - PInCk PEP Minor 0-1,499 SqFt

17K986 Plans - Plan Review Approved

Compliance Date: Not Specified

Not In Compliance

Reference - HSC - 114380

Inspector Comments: Plans are hereby approved for an existing food facility adding additional seating, walk in cooler/freezer and new handicap accessible restrooms.

Description: Thank you for your plan submittal.Plans have been approved with the following corrections.This approval does not constitute authority to violate any provision of the related codes, ordinances, or regulations, nor does it prevent further correction of errors found on the plan or with installation upon field inspection. All construction must conform to these approved plans. Alterations or changes to these plans must have review and written approval by the Plan Check Section of Environmental Health Services prior to construction.

17K247 Plans - Submittal - Remodel - Finishes

Compliance Date: Not Specified

Not In Compliance

Reference - HSC - 114380

Inspector Comments: All existing finishes are subject to final field inspection.

Description: Existing finishes are subject to evaluation by this Department. This determination will be made at the time of the preliminary field inspection. Finishes found not to be in compliance with current code requirements will not be accepted.

17K834 Plans - Submittal - Building & Safety

Compliance Date: Not Specified

Not In Compliance

Reference - Reference Number - SBC Policy

Inspector Comments: Ensure all required agencies are contacted for permitting requirements.

Description: Facility is responsible for contacting the local Planning, Building & Safety and Fire Authority for any additional requirements or construction permits prior to beginning work

17K852 Plans - Inspections Required

Compliance Date: Not Specified

Not In Compliance

Reference - HSC - 114349

Inspector Comments: Please call DEHS at 1.800.442.2283 at least one week in advance to schedule a field inspection.

Description: A preliminary inspection shall be done when the floors, walls, and ceiling finishes are complete and the equipment is in place. A final inspection will be needed in order to receive Health Permit approval from this Agency. Health permit approval is required prior to opening the food facility or storing food or beverages.When work on the project has progressed to the point of requiring an inspection, please contact us at least five (5) working days in advance in order to help us accommodate your request.

Overall Inspection Comments

Ensure storage area near the restrooms is lockable.

Signature(s) of Acknowledgement

NAME:

TITLE:

Total # of Images: 0