



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME ALTO CAMINO MHP		DATE 5/6/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 25526 REDLANDS BL, LOMA LINDA, CA 92354			INSPECTOR Veronica Vazquez	
MAILING ADDRESS 101 E REDLANDS BL STE 1800, SAN BERNARDINO CA 92408			IDENTIFIER: Pool	
TIME IN 1:26 PM	TIME OUT 2:14 PM	FACILITY ID FA0008697	RELATED ID PR0014327	PE 3620
			SERVICE: 001 - INSPECTION - ROUTINE	
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQ	
			ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	



RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

87
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	176
volume (gal)	63,281
area (sq ft)	1,725
occupancy	86

36K995 Permit - Suspension ⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Posted closure sign for spa Contact the County of San Bernardino, Division of Environmental Health Services (DEHS) when compliance is reached. Maintain pool closed until re-opened by DEHS inspector.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K995 Permit - Suspension ⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K502 Water Quality – Critical – Disinfectant level ⚠ CRITICAL ⚠

POINTS 5	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine residual above 10 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME ALTO CAMINO MHP	DATE 5/6/2015
LOCATION 25526 REDLANDS BL, LOMA LINDA, CA 92354	INSPECTOR Veronica Vazquez

36K540 Enclosure – Critical – Gates and doors self-closing and self-latching

⚠ CRITICAL ⚠

POINTS 5	Comply by: 5/20/2015	Inspector Comments: Provide one means of egress without a key for emergency purposes. Observed two pool gates that require key to exit pool area.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.

36K546 Equipment – Non-Critical - Water treatment system operation

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Repair/replace flow meter. Observed flow meter stuck at zero GPM.
	Not In Compliance	
	Violation Reference - HSC - 65525	

Violation Description: The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].

36K580 Maintenance - Spray ground requirements

POINTS 1	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	
	Violation Reference - CCR - 3106B	

Violation Description: All applicable provisions in accordance with the California Code of Regulations, Title 24, shall apply to a spray ground unless specifically addressed in section 3106B.

36K582 Maintenance - Public pool site maintenance

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Provide four food clear deck area. Observed deck area obstructed with sun chairs.
	Not In Compliance	
	Violation Reference - HSC - 65535	

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

36K596 Permit - Public Pool Closure

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Spa is hereby closed due to free chlorine residual above 10 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65545	

Description: A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

Overall Inspection Comments

Call Veronica Vazquez at (800) 442-2283 with questions.

Signature(s) of Acknowledgement

NAME:

TITLE:



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME ALTO CAMINO MHP	DATE 5/6/2015
LOCATION 25526 REDLANDS BL, LOMA LINDA, CA 92354	INSPECTOR Veronica Vazquez

Total # of Images: 0