



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | | | | |
|--|-----------------------------|---------------------------------|--|---------------------------------------|
| FACILITY NAME PALMS RIVER RESORT | | DATE 6/2/2015 | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 9/30/2015 |
| LOCATION 4170 NEEDLES HWY, NEEDLES, CA 92363 | | | INSPECTOR Melissa Nano | |
| MAILING ADDRESS 7100 W FLORIDA, HEMET CA 92545 | | | IDENTIFIER: Wading Pool | |
| | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| TIME IN 10:37 AM | TIME OUT 11:00 AM | FACILITY ID FA0007116 | RELATED ID PR0021960 | PE 3621 |
| | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE | |
| | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | |




RECREATIONAL HEALTH - Public Pool - Additional Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (°F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 64 |
| volume (gal) | 2,431 |
| area (sq ft) | 325 |
| occupancy | 32 |

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8

| | | |
|---------------------------|-----------------------------------|------------------------------------|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: |
| | Not In Compliance | Maintain a pH between 7.2 and 7.8. |
| | Violation Reference - HSC - 65530 | Observed pH of 7.9. |

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.

36K552 Equipment - Flow meter provided

| | | |
|---------------------------|--|--------------------------|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: |
| | Not In Compliance | Repair stuck flow meter. |
| | Violation Reference - CCR 24 - 3125B.3 | Observed meter stuck. |

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow and installed according to the manufacturer's written instructions with increments in the range of normal flow.

Overall Inspection Comments

If there are any questions, please contact Environmental Health Services or Melissa Nano at (800) 442-2283.

Signature(s) of Acknowledgement

Refer to Pool OIR

NAME: Refer to Pool OIR
TITLE:

Total # of Images: 0