



Public Health

Environmental Health Services

RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REP

FACILITY NAME ALTA LOMA HIGH SCHOOL		DATE 8/7/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION
LOCATION 8880 BASELINE RD, RANCHO CUCAMONGA, CA 91701			INSPECTOR Bennetta Betbadal	
MAILING ADDRESS 276 N SECOND AVE UPLAND, CA 91786			IDENTIFIER: None	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 126 - PLAN CHECK FIELD INSPECTION	
TIME IN 8:50 AM	TIME OUT 10:40 AM	FACILITY ID FA0006436	RELATED ID SR0065247	PE 3712
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 03 - REINSPECTION REQUIRED	

RECREATIONAL HEALTH PLAN CHECK - PInCk Pool New 1,000-Up SqFt

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

37K004 Access - Structure

Compliance Date: Not Specified

Inspector Comments:

Not In Compliance

Reference - CCR 24 - 3108B.1

Description: Diving boards and their supports, platforms and steps shall be substantially constructed and shall be of sufficient structural strength to carry the maximum anticipated load.

37K067 Enclosure - General - Climb

Compliance Date: Not Specified

Inspector Comments: Provide mesh for east side gate by the steps. Observed horizontal distances less than 48 inches apart.

Not In Compliance

Reference - CCR 24 - 3118B.3

Description: The enclosure shall be designed and constructed so that it cannot be readily climbed by small children. Horizontal and diagonal member designs, which might serve as a ladder for small children, are prohibited. Horizontal members shall be spaced at least 48 inches apart.

37K405 WCRR - Access Devices - Diving Board Head Room

Compliance Date: Not Specified

Inspector Comments:

Not In Compliance

Reference - SBCC - 33.1107(a)1

Description: At least 15 feet of free and unobstructed head room is to be provided above diving board and towers.

37K407 WCRR - Access Devices - Diving Board < 3 Feet

Compliance Date: Not Specified

Inspector Comments:

Not In Compliance

Reference - SBCC - 33.1107(a) 4

Description: Where a diving board not greater than one meter high is used, the water depth under the board shall be a minimum of eight feet six inches; this depth to extend a minimum of ten feet in front of the end of the board; beyond this point, the slope of the bottom upwards toward shallow water shall not be steeper than one foot vertical for each three feet horizontal. A side clearance depth of eight feet six inches shall extend a minimum of ten feet as measured from the edge(s) of the platform and/or board.

37K409 WCRR - Access Devices - Diving Boards - General

Compliance Date: Not Specified

Inspector Comments:

Not In Compliance

Reference - SBCC - 33.1107(a)

Description: Diving boards, when used, shall be installed and used only under conditions safe for both divers and bathers.

- (1) At least 15 feet of free and unobstructed head room is to be provided above diving board and towers;
- (2) No diving board or platform shall be more than ten feet above water level for unrestricted use by patrons;
- (3) Where diving boards or platforms are used, they shall be structurally sound and in good repair;

Overall Inspection Comments



Public Health
Environmental Health Services

RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REP

FACILITY NAME ALTA LOMA HIGH SCHOOL	DATE 8/7/2015
LOCATION 8880 BASELINE RD, RANCHO CUCAMONGA, CA 91701	INSPECTOR Bennetta Betbadal

Courtesy follow up inspection for per-final.

Observed a diving board is installed, not noticed during plan review. please see below for code section in regard to diving boards:

Section 3113B Diving Boards and Platforms

3113B.1 General. Diving boards and platforms shall be anchored to the pool deck, constructed of corrosion resistant material, designed and constructed to be easily cleanable and finished with a durable slip resistant material.

3113B.2 Rails and steps. Diving boards or platforms greater than 18 inches (456 mm) in height above the deck shall be provided with a ladder or stairs for access. Hand rails shall be provided at all ladders and stairs leading to diving boards or platforms more than 1 meter above the water. Diving boards and platforms that are over 1 meter above the water shall have guard rails on both sides of the diving board or platform that extend to a point on the platform directly above the water's edge. Guard rails shall be 36 inches (914 mm) above the diving board or platform.

3113B.3 Dimensions. Dimensions and clearances for the use of diving boards or platforms shall conform to those shown in Figures 31B-1 and 31B-2. Platforms and diving boards shall conform to the USA Diving Rules and Codes, Part 1, Subpart A and Appendix B, effective January 1, 2010.

As of today's inspection, there is a temporary chain fence at the west side of the pool. Permanent fence and gate will be installed prior to final inspection.

keep in mind this section of the fence and gate are subject to field inspection and approval.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0